



Ernest Sandland
Whitman Hanson School District
600 Franklin Street
Whitman, MA 02382

COLLECTED BY: Facilites

TIME: 8:05

LOCATION: Conley Sink in Nurse

CERTIFICATE OF ANALYSIS

REPORTED: 09/13/2020
ORDER #: G2051003
SAMPLE DATE: 9/4/2020
DATE RECEIVED: 9/4/2020
SAMPLE ID: Grab
DESCRIPTION: DRINKING WATER

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: <u>2051003-05</u>		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	ND

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).
Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).

Ernest Sandland
Whitman Hanson School District
600 Franklin Street
Whitman, MA 02382

COLLECTED BY: Facilities

TIME: 8:10

LOCATION: Conley Kitchen Food Prep

REPORTED: 09/13/2020
ORDER #: G2051003
SAMPLE DATE: 9/4/2020
DATE RECEIVED: 9/4/2020
SAMPLE ID: Grab
DESCRIPTION: DRINKING WATER

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: 2051003-03		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	0.001

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).

Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).



Ernest Sandland
Whitman Hanson School District
600 Franklin Street
Whitman, MA 02382

COLLECTED BY: Facilites

TIME: 8:05

LOCATION: Conley Bubbler by 18

CERTIFICATE OF ANALYSIS

REPORTED: 09/13/2020
ORDER #: G2051003
SAMPLE DATE: 9/4/2020
DATE RECEIVED: 9/4/2020
SAMPLE ID: Grab
DESCRIPTION: DRINKING WATER

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: <u>2051003-16</u>		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	ND

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).
Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).