

Ernest Sandland
Whitman Hanson School District
600 Franklin Street
Whitman, MA 02382

COLLECTED BY: Facilites

TIME: 6:56

LOCATION: HMS Nurse

REPORTED: 09/13/2020
ORDER #: G2051003
SAMPLE DATE: 9/4/2020
DATE RECEIVED: 9/4/2020
SAMPLE ID: Grab
DESCRIPTION: DRINKING WATER

CERTIFICATE OF ANALYSIS

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: <u>2051003-11</u>		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	0.001

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).

Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).

Ernest Sandland
Whitman Hanson School District
600 Franklin Street
Whitman, MA 02382

COLLECTED BY: Facilities

TIME: 6:52

LOCATION: HMS 1st Flr Bubbler

REPORTED: 09/13/2020
ORDER #: G2051003
SAMPLE DATE: 9/4/2020
DATE RECEIVED: 9/4/2020
SAMPLE ID: Grab
DESCRIPTION: DRINKING WATER

CERTIFICATE OF ANALYSIS

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: 2051003-10		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	0.002

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).

Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).



Ernest Sandland
Whitman Hanson School District
600 Franklin Street
Whitman, MA 02382

COLLECTED BY: Facilities

TIME: 6:58

LOCATION: HMS Kitchen

REPORTED: 09/13/2020
ORDER #: G2051003
SAMPLE DATE: 9/4/2020
DATE RECEIVED: 9/4/2020
SAMPLE ID: Grab
DESCRIPTION: DRINKING WATER

CERTIFICATE OF ANALYSIS

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL ¹ / Rec. Limit ²	Result
Test Parameters				LAB-ID#: 2051003-18		
Lead 200.8	EPA 200.8	09/08/2020	mg/L	0.001	0.015 ¹	0.001

Unless otherwise noted, all analyses were conducted by Analytical Balance Corp. (M-MA022).
Chemically, this water meets the Maximum Contaminant Level requirements as established by the Commonwealth of Massachusetts for drinking water (for the parameters tested).